



# User/Owner Decision Tree

## Does PSSR 2000 Apply to My Pressure System?

### Start

#### Is there a relevant fluid in the system?

(Relevant fluid = steam, gases under pressure, or fluids at pressures above 0.5 bar, as defined by Reg 2 PSSR)

yes

yes

yes

#### Does the system include a pressure vessel that either:

Contains steam, or has pressure x volume product of **250 bar litres** or more?

#### Is the system mobile or subject to a lease/hire agreement?

**PSSR 2000 does not apply**

**PSSR Regulations 5(4)\*, 8\*, 9\*, 10\*, and 14\* do not apply**

**The user has duties under PSSR**

**The owner has duties under PSSR**

### If PSSR applies, you must comply with the following regulations (as relevant):

**Regulation 5** - Provision of information and marking

**Regulation 7** - Safe operating limits

**Regulation 8** - Written Scheme of Examination \*

**Regulation 9** - Examination in accordance with the Written Scheme \*

**Regulation 10** - Action in case of imminent danger \*

**Regulation 11** - Operation

**Regulation 12** - Maintenance

**Regulation 14** - Keeping of records \*

**Regulation 15** - Precautions to prevent pressurisation of certain vessels (user only)



This decision tree only applies to type (a) pressure systems as defined in Regulation 2(1) PSSR: one or more pressure vessels of rigid construction, any associated pipework and protective devices.

It does not apply to type (b) pressure systems (pipework with protective devices for transportable receptacles) or type (c) systems (pipelines and their protective devices).

Always refer to the (PSSR) Pressure Systems Safety Regulations 2000 (SI 128) and the HSE Approved Code of Practice L122 for full requirements.

